

FIRST INFORMATION REPORT



First Information of a cognizable crime reported under section 154 Cr. P. C. at PS

1. Dist. PURULIA Sub-Divn. Jhalda P.S. Bachmundi Year 2023 FIR No. 123/23 Date 14/10/23

2. i) Act. - Sections. - ii) Act. - Sections. -

3. a) General Diary Reference : Entry No. 596 (1)(b) of Electricity Act 2003 & Amendment Act 2007 Time 17:15 hrs

b) Occurrence of Offence : Day Tuesday Date 10.10.2023 Time -

c) Information received Date 14-10-2023 Time 17:15 hrs G.D. No. 596 at the P.S.

4. Type of Information : Written / Oral Tyred

5. Place of Occurrence : a) Direction and Distance from P.S. approx 2 km south-east from ps.

b) Address - Beat No. JL No. 92 Area-D Bachmundi

c) In case outside limit of this Police Station, then the name of P.S. - District -

6. Complainant / Informant :

a) Name BISWANATH BANUI

b) Father's / Husband's Name SWADESH RANJAN BANUI

c) Date / Year of birth NOT NOTED d) Nationality INDIAN

e) Address A.E. (SOLD) PURULIA REGIONAL OFFICE - W.B. S.E.D.C.L

7. Details of known/suspected /unknown/accused with full particulars

(Attach separate sheet, if necessary) :
Bhajan Kumar
510 Chyama Das Kumar
4-Songra
Ps-Bachmundi
DIST-PURULIA

8. Reasons for delay in reporting by the complainant/informant. -

9. Particulars of properties stolen/involved : (Attach separate sheet, if required) : one no tampered meter bearing meter no BE0407446 make Bostee BLANIR 5000
PS-HL

10. Total value of properties stolen/involved -

11. Inquest report/U.D. Case No., if any : -

12. FIR Contents : (Attach separate sheet, if required) The original written complaint of the complainant which is part of F.I.R. is attached here with

Bodhraj
OFFICER-IN-CHARGE
BACHMUNDI P.S.
DIST-PURULIA

13. Action taken : Since the above report reveals commission of offence(s) u/s 135 (1)(b) & (c) of Electricity Act 2003 & Amendment Act 2007

registered the case and took up the investigation/directed PS BUDHESWAR MAJHI to take up the investigation/transferred to P.S. - on point of jurisdiction. FIR read over to the Complainant/informant, admitted to be correctly recorded and a copy given to the Complainant/informant free of cost.

Sayal Mishra
OFFICER-IN-CHARGE
BACHMUNDI P.S.
DIST-PURULIA

Biswanath Banui

Signature / Thumb impression of the Complainant/informant

Bodhraj
OFFICER-IN-CHARGE
BACHMUNDI P.S.
DIST-PURULIA

Signature of the Officer-in-Charge, Police Station with Name SAYAL MISHRA
Rank SUB-INSPECTOR OF POLICE
Number if any DIST-PURULIA

To

The Inspector-In-charge
Bagmundih Police Station
At-Bagmundih
Dist-Purulia

Subject: - FIR against Bhajan Kumar(user), Son of Late Shyamapada Kumar, resident of Vill Saragdih , PO Bagmundih, ,PS Bagmundih , Dist Purulia .

Dear Sir,

I do hereby lodge complaint empowered by the Electricity Act 2003, Amendment of 2007 to the effect that, the below mentioned accused, has committed theft & unauthorized use of electricity U/S 135 (1)/(b) & (1)/(d) of the electricity Act 2003, Amendment of 2007 as stated here under.

On 10/10/2023 at 17:45 Hrs. I, Biswanath Barui (AE S&LP attached to Purulia Regional Office WBSEDCL) along with Promod Ranjan Barman (Special officer attached to Purulia Regional Office, Anup Mondal (JE-1 Bagmundih CCC), Sankar Ch Mahato (ACM Purulia Regional Office WBSEDCL) and Dayamay Mahato (Sr TSH Purulia Region Office WBSEDCL) went to make an inspection to workout upon a source information regarding theft of electricity at the domestic premises of user Bhajan Kumar, Son of Late Shyamapada Kumar, resident of Vill Saragdih , PO Bagmundih, ,Bagmundih PS , Dist Purulia .

During the time of inspection at the premises 1 no of electricity meter were found having serial no BE0407446(Consumer id 200254385, Consumer Name- Late Shyamapada Kumar).

It was observed that accused user Bhajan Kumar has made unauthorized use of electricity under section 135 1/b & 1/d by tempering/damaging meter serial no BE0407446 by means of creating a hole and inserting gum inside the meter, which interfere with accurate or proper registration of electricity consumption and hence causing huge loss of revenue to WBSEDCL. From the above arrangement the accused was using Fan 4 nos (70 watt each) , Light 10 nos (12 watt each) , Pump 1 nos 746 watt , TV 1 nos 180 watt each , Fridge 1 nos 175 watt each.

After detection of theft & unauthorized use of electricity illegally and dishonestly, the inspection team disconnected the service lines in the same premises from pole with the help of LT Mobile Van Team and removed & seized 1 nos of damaged energy meter bearing meter no BE0407446. Prepared seizure list and inspection report. Accused refused to sign the seizure and inspection documents.

The inspection team left the premises at about 18:15 Hrs on 10th Oct 2023.

The accused committed theft of electricity U/S 135 (1)/(b) & (1)/(d) of the electricity Act 2003, Amendment of 2007.

You are requested to take cognizance of the complaint & treat this as FIR and take necessary action.

Encl:-

1. Inspection sheet
2. Seized article as per seizure list
3. seizure list.

Yours faithfully

Biswanath Barui

A.E (S&LP) PRO
S/o - Suresh K. Barui
A.E (S&LP)
- Purulia Regional Office
W.B.S.E.D.C.L

Purulia Regional Office

Received on-14-10-2023
one started Bagmundih
PS case no- 133/23 dt-14-10-23
U/s-135(1)(b) & (1)(d)
of Electricity Act-2003
Amendment Act-2007

14/10/23
OFFICER-IN-CHARGE
BAGMUNDIH P.S.
DIST.-PURULIA

West Bengal State Electricity Distribution Company Limited

(A Government of West Bengal Enterprise)

INSPECTION ON L & M V CONSUMER

S & L P Inspection Team

HQ. Corporate, Vidyut Bhaavan / Purulia Divn. / Region

Name of the Consumer : Shyamapada Kumar, user Bhajan Kumar Date of Inspection : 10.10.2023
 Site Address (P.O.S) : Sakagdi Category of Consumer : Ind. / Com. / Dom. / O.
 Consumer Id : 200254385 Nature of production : Domestic
 Name of C.C.C. : Baghmundi Contractual Load (KW/HP/KVA) :
 Name of the Division : Purulia MFG - 9/2022
Inspected Load :- 150L watt.

Technical Details

1. Meter Details : Make Bentec WBSSEDCL No. BE0407446 Volt 1X240 Amps 5-30 Meter Constant 3200
 As Inspected :
 As per Card / Bill :

SEALS	Existing No.	Remarks	New No.
i) PR box (upper)			
ii) PR box (lower)			
iii) Meter terminal cover (L/R)	<u>SE0610826</u>		
iv) Meter body (SEDCL) (L/R)			
v) Meter body (Mfg.) (L/R)			
vi) Op. Port			
vii) 4/5 Level security seal (L/R)			

3. PR box conditions : Staandard / Non-Standard. OK / Not OK
 4. Meter Status : Sticky / Stop / Burnt / No display / Running / With Display
 5. Meter reading on date :
 6. Last 3 reading with date : 335 dt - 10.10.2023
 7. Meter terminal voltage (line / display) in volts. : $V_{RN} (_ / _)$ $V_{YN} (_ / _)$ $V_{BN} (_ / _)$
 8. Load in Amps (Line / Meter display) : $I_R (_ / _)$ $I_Y (_ / _)$ $I_B (_ / _)$
 9. Bias current (pot. ckt.) in mA : R — Y — B —
 10. Observed load (in KVA) : (physical) (meter) observed pi-
 11. Phase sequence : Forward / Reverse Installed CTR :
 12. Observation :

After inspection it was found The consumer uses electricity unauthorisedly through tampered meter & found a hole by pushing Gum for not proper recording energy in energy meter.

13. Theft of Energy detected or not :
 Means of Theft, if detected :

yes.

Consumer/User/Representative

1. Name :
 Relationship/Designation :
 Signature :

Representative of C.C.C.

1. Name : A. Mondal
 Designation : JE-1
 Signature : Amp Mondal

S&LP Inspection Team Official

1. Name : B. N. Barmu
 Designation : AE (S&LP) PRO
 Signature : Barmu
10.10.23

2. Name :
 Relationship/Designation :
 Signature :

2. Name :
 Designation :
 Signature :

2. Name : S. Ch. Mahato
 Designation : ACM (S&LP) PRO
 Signature : S.Ch. Mahato

Local Witness :

Name

Father's Name

Village

P.S.

Signature

1.

2.